

---

RFP ADDENDUM

ADDENDUM NO.: 004

DATE ISSUED: August 27, 2024

BID DATE: Friday, August 30, 2024

BID TIME: 2:00 PM ET

BID LOCATION: City of Dalton Finance Department

CLARIFICATIONS:

1. The following VAV boxes are not in agreement with the “as built” drawings:
  - a. VAV 108 is approximately 6'-0” east from the as-built location.
  - b. VAV 112 is approximately 14'-0” north from the as-built location.
  - c. VAV 306 is located in the attic, not the third floor ceiling.
  
2. Drawing M1.2 - HVAC Piping Plan Level 2:
  - a. There is not a VAV 211.
  - b. Lobby 202 is conditioned via VAV 203.
  - c. The thermostat in Elevator Lobby 201 controls VAV 204.