

---

RFP ADDENDUM

ADDENDUM NO.: 002

DATE ISSUED: August 21, 2024

BID DATE: Tuesday, August 27, 2024

BID TIME: 2:00 PM ET

BID LOCATION: City of Dalton Finance Department

ADDENDUM NO. 1 CLARIFICATION:

1. City of Dalton Fire Marshall Comments:

- a. Existing smoke evacuation system to be tested by Owner separately from HVAC Replacement project.
- b. At the end of the HVAC Replacement project, the City of Dalton Fire Marshal will test the existing fire alarm system to ensure dampers and shut down are properly connected.