

---

CONTRACT ADDENDUM

ADDENDUM NO.: 007

DATE ISSUED: October 18, 2024

BID DATE: Friday, October 25, 2024

BID TIME: 3:00 PM

BID LOCATION: Dalton City Hall Finance Department

CONTRACTOR ACTION:

1. Acknowledge receipt of this addendum by writing in "Addendum No. 7" on page 0200-3 of bid proposal.

INTERPRETATIONS:

1. *Question:* The plumbing drawings call out tile showers for the concession building but there are no specs or details referring to the tile.

City of Dalton Response: There is no tile for the concession building. See revised drawing.

2. *Question:* Drawing E101 shows two (2) fans per court as part of the bid alt 1 but the mechanical drawings show one (1) fan per court. Which is preferred?

City of Dalton Response: Alt 1 should include two (2) fans per court. See revised drawing.

ADDITIONAL INFORMATION:

1. Addenda No. 006 published on October 21st, 2024 contained an error. As changed on Addendum No. 005 Line 25 black chain line fence is 427 LF. Updated bid list is attached.

BY:

Will Chappell  
Assistant Parks and Recreation Director

###

City of Dalton  
Pickleball Facility



8/21/2024

ITEM No.	DESCRIPTION	ESTIMATED QUANTITY	UNIT OF MEASURE	UNIT PRICE	TOTAL PRICE
<b>SITE IMPROVEMENTS</b>					
1.	Clearing, Demolition & Grubbing	1	LS		
2.	Mobilization and Demobilization	1	LS		
3.	Grading Complete	1	LS		
4.	Asphalt Pavement Patch	11	SY		
5.	6" Graded Aggregate Base Course	185	SY		
6.	24" Curb and Gutter	24	LF		
7.	Concrete Paving (4" Thick)	2,100	SY		
8.	Concrete Paving (6" Thick)	185	SY		
9.	ADA Ramp (Retaining Wall, Handrail Included)	1	LS		
10.	Site Stairs with handrails	2	EA		
11.	Wheel Stop	17	EA		
12.	Parking/Roadway Signage	1	LS		
13.	Shade Canopy	4.0	EA		
14..	Bench	31	EA		
15.	Bike Rack	4	EA		
16.	Trash Bin	6	EA		
17.	Picnic Table	4	EA		
<b>STORM SEWER SYSTEM</b>					
18.	Storm Drain Pipe, RCP				
A.	15-inch	30	LF		
B.	18-inch	275	LF		
C.	24-inch	170	LF		
D.	30-inch	106	LF		
19.	12" Storm Drain Pipe W/Clean Out, HDPE	319	LF		
20.	12" Atrium Drain Inlet	2	EA		
21.	12" Trench Drain	170	LF		
22.	4" Underdrain (Fabric, Gravel Included)	24	LF		
23.	Precast Drop Inlet, Type A (W/Grate Top)	5	EA		
24.	Concrete Headwall	4	EA		
25.	Outlet Control Structure	1	LS		
26.	8' Black Vinyl Chain Link Fence (Gate Included)	427	LF		
<b>SANITARY SEWER AND WATER UTILITIES</b>					
27.	4" DIP Sanitary Sewer Lateral (Fittings, Caps, Clean Outs Included)	215	LF		
28.	Connect Sewer Lateral Pipe to Exist. Sewer Main	1	EA		
29.	Sanitary Sewer Manhole	1	EA		
30.	Sanitary Sewer Dog House Manhole	1	EA		
31.	6" Fire Hydrant Assembly	1	EA		
32.	8"x6" Tapping Saddle and Valve	1	EA		
33.	2" Tapping Saddle and Valve	1	EA		



34.	6" DIP Water Line (taps, fittings, valves included)	19	LF				
35.	2" DR 9 HDPE Water Line (Fittings, Valves included)	275	LF				
36.	2" Water Meter	2	EA				
37.	2" Backflow Preventer	2	EA				

**MISCELLANEOUS**

38.	Building Complete	1	LS				
39.	Site Electrical Complete	1	LS				
40.	Pickleball Court Complete	15	EA				
41.	Landscaping Complete	1	LS				
42.	Irrigation System Complete	1	LS				
43.	Erosion Control/BMPs (All Items As Shown On Plans)	1	LS				
44.	Storm Water Sampling for NPDES Permit	1	LS				
45.	Monitoring, NOI, NOT, Record Keeping & Reporting NPDES to GA EPD	1	LS				
46.	Materials Testing	1	LS				
47.	Monument Sign	2	LS				

**TOTAL AMOUNT BASE BID**

(In Figures)

(In Words)

**ALTERNATE BID 1**

Item No.	DESCRIPTION	ESTIMATED QUANTITY	UNIT OF MEASURE	UNIT PRICE	TOTAL PRICE
<b>STREET IMPROVEMENTS</b>					
1.	Pickleball Court Covering (68'W x 220'L) 18' Eave Pavilion Structure (ADD)	1	LS		
2.	Pickleball Court Covering Foundation System Complete (ADD)	1	LS		
3.	Pickleball Court Covering Electrical, Lighting and Fans (ADD)	1	LS		
4.	Shade Canopy (DEDUCT)	2	EA		
5.	Site Pole Lighting, Type P1 (DEDUCT)	8	EA		
6.	Site Pole Lighting, Type P2 (DEDUCT)	8	EA		

**TOTAL AMOUNT ALTERNATE BID No. 1**

(In Figures)

(In Words)

